# Energy Surety Microgrids™ Supporting Renewable Technologies and Energy Assurance


Abbas Akhil and Mike Hightower Sandia National Laboratories

aaakhil@sandia.gov (505) 844-7308

mmhight@sandia.gov (505) 844-5499

Partners in Environmental Technology
Technical Symposium and Workshop
Washington DC
November 30, 2010





#### **Report Documentation Page**

Form Approved OMB No. 0704-0188

Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.

1. REPORT DATE 30 NOV 2010	2. REPORT TYPE	3. DATES COVERED <b>00-00-2010 to 00-00-2010</b>	
4. TITLE AND SUBTITLE Energy Surety Microgrids(tm) Supporting Renewable Technologies and Energy Assurance		5a. CONTRACT NUMBER	
		5b. GRANT NUMBER	
		5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)		5d. PROJECT NUMBER	
	5e. TASK NUMBER		
	5f. WORK UNIT NUMBER		
7. PERFORMING ORGANIZATION NAME(S) AND AI Sandia National Laboratories,1515 Eu 1108,Albuquerque,NM,87123	8. PERFORMING ORGANIZATION REPORT NUMBER		
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)		10. SPONSOR/MONITOR'S ACRONYM(S)	
		11. SPONSOR/MONITOR'S REPORT NUMBER(S)	

12. DISTRIBUTION/AVAILABILITY STATEMENT

Approved for public release; distribution unlimited

#### 13. SUPPLEMENTARY NOTES

Presented at the 15th Annual Partners in Environmental Technology Technical Symposium & Workshop, 30 Nov ? 2 Dec 2010, Washington, DC. Sponsored by SERDP and ESTCP. U.S. Government or Federal Rights License

#### 14. ABSTRACT

For the DoD, the success of military operations depends on the ability to maintain critical capabilities at fixed and forward bases, and to maintain tactical operations. Maintaining these critical functions and operations has become increasingly dependent on having secure and reliable supplies of energy. Traditionally, military bases often rely heavily on public utilities as the primary electricity, natural gas, and other energy need providers, and install back-up generation (typically diesel or natural gas) to supply peak or emergency energy supplies. In many cases, these generators are undersized, improperly located, and poorly maintained such that they cannot effectively meet critical mission energy needs for extended periods. Several groups, including Sandia National Laboratories, have been looking at approaches to integrate distributed energy generation, such as photovoltaic, wind, plug-in-hybrids, waste-toenergy systems, microturbines, and energy storage systems into one or more microgrids to improve base energy supply reliability and enhance critical mission assurance. This presentation will provide information on many common energy security and reliability pitfalls and concerns at military bases assessed by Sandia, and discuss considerations and analyses needed to integrate renewable distributed generation technologies into an energy surety microgrid and the associated energy security, reliability, benefits, and costs as well as environmental benefits.

15. SUBJECT TERMS

16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF	18. NUMBER	19a. NAME OF
			ABSTRACT	OF PAGES	RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT <b>unclassified</b>	c. THIS PAGE unclassified	Same as Report (SAR)	14	

Standard Form 298 (Rev. 8-98) Prescribed by ANSI Std Z39-18

# ENERGY SURETY MICROGRIDS – SUPPORTING RENEWABLE TECHNOLOGIES AND ENERGY ASSURANCE

MR. MIKE HIGHTOWER
Sandia National Laboratories
1515 Eubank SE
MS 1108
Albuquerque, NM 87123
(505) 844-5499
mmhight@sandia.gov

For the DoD, the success of military operations depends on the ability to maintain critical capabilities at fixed and forward bases, and to maintain tactical operations. Maintaining these critical functions and operations has become increasingly dependent on having secure and reliable supplies of energy. Traditionally, military bases often rely heavily on public utilities as the primary electricity, natural gas, and other energy need providers, and install back-up generation (typically diesel or natural gas) to supply peak or emergency energy supplies. In many cases, these generators are undersized, improperly located, and poorly maintained such that they cannot effectively meet critical mission energy needs for extended periods.

Several groups, including Sandia National Laboratories, have been looking at approaches to integrate distributed energy generation, such as photovoltaic, wind, plug-in-hybrids, waste-to-energy systems, microturbines, and energy storage systems into one or more microgrids to improve base energy supply reliability and enhance critical mission assurance.


This presentation will provide information on many common energy security and reliability pitfalls and concerns at military bases assessed by Sandia, and discuss considerations and analyses needed to integrate renewable distributed generation technologies into an energy surety microgrid and the associated energy security, reliability, benefits, and costs as well as environmental benefits.

# Common Military Base Electric Power Security and Reliability Issues


- Power outages occurring as many as 300 times per year at some bases
  - Low maintenance and understanding of back up generation
    - Low probability of start when needed (60%)
    - Operations for extended periods limited,
    - Often over or under designed and support only one building
- Radial electric power feeder systems could provide redundancy but are often not interconnected
- Substations commonly outside base control and often a common point of failure for base feeders
- Lack of critical mission understanding and energy needs
  - Varying drivers by base commander, tenant commanders, and utility managers

Lack of Strategic Energy Security and Reliability Approach





# **Example of Common Backup Generator Configurations**



# 2010 QDR Provides Guidance on Domestic Facility Energy Security

### Defines Energy Security


• "Energy security for the Department means having <u>assured</u> access to <u>reliable</u> supplies of energy and the ability to <u>protect</u> and deliver <u>sufficient</u> energy to meet operational needs"

#### Directs facilities to:

- Address energy security while simultaneously enhancing mission assurance
- Conduct a coordinated energy assessment to prioritize critical assets
- Promote investments in energy efficiency
- Ensure that critical assets are prepared for prolonged outages: natural disasters, accidents, attacks


**Energy Assurance = Energy Reliability, Security, Sufficient** 





# Energy Surety Microgrid™ Approach to Energy Assurance


With distributed generation and storage on distribution side, electric power can be provided when the grid is down



Generator

كەك

Storage and generation on load side sized to match energy system performance needs



# General Microgrid Characteristics and Benefits


### **Key Attributes (Defining Characteristics):**

- Grouping of interconnected loads and distributed energy resources
- Can operate in both island mode or grid-connected
- Acts as a single controllable entity to the grid

### **Key Benefits (Military and Civilian)**

- Enables faster Grid modernization
- Enhances use of distributed and renewable energy resources
- Improves local energy flexibility, security, and reliability
- Supports improved Grid management and operation






# Renewable and Distributed Generation to Support Microgrids

- Small combustion and µ-turbines
- Fuel cells
- IC engines
- Small hydro and wind
- Solar electric and solar thermal
- Energy storage (batteries, flywheels,...)
- Plug in hybrid vehicles
- Small nuclear power

**Small Commercial** 

Commercial



Sandia National Laboratories

From 10-kW to 50-kW, typically three phase


Greater than 50-kW up to 10MW




# Sandia's Energy Surety Microgrid™ (ESM™)

- Internally funded and developed as part of critical energy infrastructure protection and renewable energy research programs
- Integrates and controls dispersed loads and sources to operate in both islanded and grid-tied configurations
- Key features of ESM<sup>™</sup>
  - Improved energy assurance (safety, security, reliability)
  - Facilitates integration of renewable resources and DG
  - Offers opportunities for CHP/Tri-power greater fuel and energy efficiency
  - Reliability stated in terms of mission impact
    - Rather than in 9's of reliability






# Sandia ESM™ uses Risk-based Method for Energy System Assurance Design




# Design Approach for Military Applications

- Utilize existing backup generation where possible to reduce system costs (new generation and storage), and provide microgrid with a well-behaved operational performance backbone
- Include new generation/energy sources as needed for creating a microgrid interconnecting mission critical facilities and support functions
- Include cyber-secure, semi-autonomous, command/control of microgrid loads and generation for operational flexibility and cost savings opportunities
  - Peak shaving, emergency operations, and utility grid support





## **Example Microgrid Design for Energy Assurance**




# Benefits of Energy Surety Microgrid Design Approach

### Provides tools and approach to:

- Identify and quantify critical mission energy needs and create an effective energy assurance strategy
  - Focus upgrades and configuration changes to improve overall system performance, reliability, and mission assurance
- Matches energy system assets (generation and storage) to meet critical mission energy performance needs
  - Supports the location, sizing, and integration of distributed and renewable energy resources for more efficient operation
  - Can more easily quantify cost/benefits of energy reliability and security
- Energy security focus and "grid-tied" and "islanded" operational capability encourages renewable use
  - Enhances opportunities for demand management and changes in time-of-day operations, promotes CHP and Trigen integration, allows higher penetration of renewables





# Current Sandia Military Microgrid Conceptual Design Efforts

### Army

 Ft Sill, Ft. Bliss, Ft. Belvoir, 99<sup>th</sup> Air Guard (Ft. Devens), Ft. Carson

### Navy/Marines

- Indian Head, Camp Smith
- PACCOM/NORTHCOM JCTD

#### Air Force

 Maxwell, Kirtland, Vandenberg, and Schreiver

#### FY 11 project interest

 Philadelphia Navy Yard, Aberdeen, Travis AFB, Cannon AFB, West Point, NAVFAC (Norfolk)



